

From: [Brian Moore](#)
To: [Zehner, Warren](#); [Abshire, David](#)
Cc: [Bob Piniewski](#)
Subject: Malone-EPA ER Injection-Week 24 Summary
Date: Tuesday, December 22, 2015 8:44:28 AM
Attachments: [Malone-Injection Well Summary Table-Week 24.pdf](#)

Dear Warren and David,

Below please find a general weekly update discussing injection under EPA ER at the Malone Service Superfund Site in Texas City, TX. Attached please find the injection summary table.

There is approximately 4.5 MM gallons of contact water on-site. The site received 0.1" of rain on Wednesday.

Warren: The MCP has received a signed ESD from the EPA which will be effective on January 19, 2016 after the comment period expires. With the 4.5 inches of rain last week we still have a large volume of water to inject. Our last conversation you were planning on a site visit the week of January 9th. Please let me know what day that week or if you decide to push the site visit back so I can schedule to be on-site. Thanks.

Monday 12/14/15- WDW-138: Contact water injection non-stop. WDW-73: Contact water injection during working hours.

Tuesday 12/5/15- WDW-138: Contact water injection, auto shutdown due to bad belts on annulus pump, repair made same day . WDW-73: Contact water injection during working hours, auto shutdown due to injection pump packer leaking, scheduled repair for tomorrow.

Wednesday 12/16/15- WDW-138: Contact water injection non-stop. WDW-73: Contact water injection during working hours, replaced packing in injection pump.

Thursday 12/17/15- WDW-138: Contact water injection non-stop. WDW-73: Contact water injection during working hours.

Friday 12/18/15- WDW-138: Contact water injection non-stop, shutdown COB. WDW-73: Contact water injection during working hours.

Should you have any questions please let me know. Have a Merry Christmas and safe New Year!

Kindest Regards,

Brian Moore
Construction Manager
Malone Service Superfund Site RD/RA



9716153

Project Navigator, Ltd.

15990 N. Barkers Landing, Ste. 325

Houston, TX 77079

Direct: 713.468.5961

Cell: 713.534.4546

Fax: 713.468.4515

E-MAIL NOTICE; This transmission may be (1) subject to Attorney-Client Privilege, (2) an attorney work product, or (3) strictly confidential. If you are not the intended recipient of this message, you may not disclose, print, copy or disseminate this information. If you have received this in error, please notify the sender only and delete the message.